

TITLE: MITIGATION OF THE RISKS OF INFLOW AND INFILTRATION IN
NEW SANITARY SEWER SYSTEMS

MODIFICATION NO. 1 TO THE DOCUMENT

DATE: 2025-10-02

ERRATA

Clause 5.3.2.5.6 Piping connected to hangers attached to foundation wall (p. 26)

The point a) has been modified, so that it is now worded as follows:

a) use 19 mm [3/4 in] wide 20-gauge galvanized steel straps;
